

## Alarm Bells

## S-SSM 24-6

### General

System Sensor's SSM Series alarm bells are low-current, high-decibel notification appliances for use in fire and burglary systems or other signaling applications. They come pre-wired to reduce installation time, and also incorporate a polarized electrical design for use with supervision circuitry.

With reliable performance, SSM Series alarm bells provide loud, resonant tones. They operate on 24 VDC and are motor driven. SSM Series alarm bells offer simplified installation. For indoor use, SSM Series alarm bells mount to a standard 4" (10.16 cm) square electrical box. For outdoor applications, a WBB weatherproof back box is used.

### Features

- Approved for indoor or outdoor (with WBB back box) use.
- Low current draw.
- High dB output.
- Three sizes available: 6" (15.24 cm), 8" (20.32 cm), and 10" (25.40 cm) diameter.
- 24 VDC models; polarized for use with supervision circuitry.
- Bells mount directly to standard 4" (10.16 cm) square Electrical box.

### Specifications

**Nominal voltage:** 24 VDC.

**Operating voltage range:** 19.2 to 26.4 VDC.

**Average current draw:** 0.03 A.

**Sound output:** 85 dB.

**Operating temperature range:** -31°F (-35°C) to +140°F (+60°C).

**Termination:** provided with two sets of leads for in/out wiring.

**Service use:** Fire Alarm, General Signaling, Burglar Alarm.

### Engineering and Architectural Specifications

Model shall be a SSM Series alarm bell. Bells shall have under dome strikers and operating mechanisms. Gongs on said bell shall be no smaller than nominal 6" (15.24 cm), 8" (20.32 cm), or 10" (25.40 cm) (specify size) with an operating voltage of 24 VDC. Bells shall be suitable for surface or semi flush mounting. Outdoor surface-mounted installations shall be weatherproof (using optional WBB weatherproof back box); otherwise, bells shall mount to a standard 4" (10.16 cm) square electrical box having a minimum projection of 2.5" (6.35 cm).



Bells shall be located as shown on the installation drawings or as determined by the Authority Having Jurisdiction. Bells shall be Listed for indoor/outdoor use by Underwriters Laboratories, ULC (Canada), and the

### Agency Listings and Approvals

These listings and approvals apply to the modules specified in this document. In some cases, certain modules or applications may not be listed by certain approval agencies, or listing may be in process. Consult factory for latest listing status.

- UL Listed: S4011
- ULC Listed: S7539 (SSM24-6A, SSM24-8A, SSM24-10A)
- MEA Listed: 331-01-E
- FM Approved
- CSFM: 7135-1653:125